

Addendum #2
Water Main for 2018
Due Thursday, February 22, 2018 at 11:00 a.m.

at
Wayne County Water & Sewer Authority Office
3377 Daansen Road, Walworth, New York

Please replace the PVC PIPE Spec on page 4 of the bid documents with the following.

POLYVINYL CHLORIDE (P.V.C.) PIPE

Pipe shall be Polyvinyl Chloride Pipe, 4" through 12", conforming to the requirements of AWWA C900-16, or current standard, Class 235, (DR-18) as specified with plans, gasket joints, integral bells and rubber gaskets.

All pipes shall be of good quality and free from defects which would make it unfit for the use intended, all pipe shall be a true circle in section with concentric inner and outer surfaces. Pipe to be cut during installation shall be fully gauged for field cutting.

All pipes shall be appropriately covered and/or capped at each end with a suitable plastic cover or acceptable alternate so that the interior length of the pipe is protected during transportation and storage and is not exposed to the environment.

Acknowledgement of receiving this Addendum must be included with the bid submission.

Addendum Received: _____

Print Name

Signature

Date