

## **Addendum #1**

### **Commonly Used Materials Bid**

Due Thursday, August 20, 2020 at 11 a.m.

at

Wayne County Water & Sewer Authority Office 3377 Daansen Road Walworth, New York

#### **Responses to submitted questions:**

**Q 1:** Will the Smith-Blair 421 Top Bolt Coupling be considered and or equal to Hymax?

**A 1:** **No, the Smith-Blair will not be considered for this Commonly Used Materials bid.**

**Q 2:** Can the Clow Eddy Hydrant be considered and or equal?

**A 2:** **No, acceptable hydrant manufacturers/models are Kennedy K81D, AVK Nostalgic, Mueller Centurion.**

**Q 3:** I see that Bibby-Ste-Croix is listed under the Valve Box and Parts Section which has to be certified as AIS Compliant. I was under the assumption that Bibby could not meet the criteria. Please clarify.

**A 3:** **It was our error to include Bibby-Ste-Croix as an acceptable product, since their valve boxes and parts are manufactured in Canada and are not AIS compliant. Please exclude Bibby-Ste-Croix as an acceptable product.**

**Acknowledgement of receiving this Addendum must be included with the bid submission.**

Addendum Received: \_\_\_\_\_

Print Vendor Name

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Date